



CURBSIDE - SIDEWALK APRON FOR 5' WALKS

SLOPE:

50: 1 (2%)

12: 1 (8%)

NOTES:

1. ALL CONCRETE SHALL BE 6" INCH MINIMUM THICKNESS OF 3,000 psi. FIELD STRENGTH
2. ADD JOINT IN CENTER OF APRON AND CURB & GUTTER WHEN APRON WIDTH EXCEEDS 20' FT.
3. ALL SLOPES ARE RELATIVE TO HORIZONTAL.
4. IF THE APRON WILL ALSO SERVE AS A SIDEWALK ACCESS RAMP IN PLACE OF A STANDARD RAMP, THE APRON SLOPE FROM THE GUTTER TO THE SHALL BE 12: 1 OR LESS WITH NO LIP.

**CITY OF FLORENCE
STANDARD DRAWING**

**DRIVEWAY AND
ALLEY APRON
5' CURBSIDE
SIDEWALK**

DATE:

9-22-11

DRAWING NO.

F-208B