



**NOTES:**

1. STANDARD PRECAST MANHOLE SECTION DIAMETER SHALL BE 48". USE 42" ONLY IF SPECIFIED BY THE ENGINEER.
2. ALL CONNECTING PIPES SHALL HAVE A FLEXIBLE JOINT WITHIN 18" OF MANHOLE WALL.
3. SEE MANHOLE BASE SECTION DRAWING FOR BASE DETAILS.
4. ALL MANHOLES SHALL BE VACUUMED TESTED.
5. MAX. 350' BETWEEN EACH MANHOLE (UNLESS OTHERWISE APPROVED).
6. SANITARY MANHOLES PLACED IN CENTER OF STREET.

<b>CITY OF FLORENCE STANDARD DRAWING</b>	
<b>MANHOLE</b>	
DATE: MARCH-2012	DRAWING NO. F-315