



NOTES

1. FOR BLOW-OFF OPERATIONS, REMOVE PIPE CAP AND ADD A 2" PIPE EXTENSION AND 2" CHECK VALVE ASSEMBLY.
2. BACK-FLOW PREVENTION DEVICES REQ'D FOR ALL BLOW-OFF ASSEMBLIES.

**CITY OF FLORENCE  
STANDARD DRAWING**

**6" BLOWOFF  
ASSEMBLY**

DATE: 9-23-11

DRAWING NO. F-405