



NOTES:

1. AIR-RELEASE AND VALVE ASSEMBLIES SHALL BE INSTALLED AT HIGH POINTS. THE BREATHER TUBE SHALL EXTEND ABOVE GROUND AND PROVIDED WITH DOWNWARD FACING, SCREENED ELBOW.
2. PIPE AND VALVE SIZES SHALL BE SPECIFIED FOR EACH PROJECT BY THE ENGINEER.

CITY OF FLORENCE STANDARD DRAWING	
COMBINATION AIR RELEASE AND VALVE ASSEMBLY 2" AND SMALLER	
DATE: 9-23-11	DRAWING NO. F-407