

Insulation Checklist

- | | | |
|----------|--|-------------|
| 1 _____ | Is address plainly posted and legible from street? | R321 |
| 2 _____ | Is there a complete set of approved plans on the jobsite? | R106.3.1 |
| 3 _____ | Is the permit sign off card posted on the jobsite? | R117.1 |
| 4 _____ | Does the insulation meet the R value on the plans? Table | N1104.1(1) |
| 5 _____ | Do all windows/doors meet the U value on the plans? Table | N1104.1.(1) |
| 6 _____ | Are batts used where there is less than 44" attic headroom? | N1104.2.1 |
| 7 _____ | Are vent openings adequately baffled for attic insulation? | N1104.2.1 |
| 8 _____ | All door/window frames and exterior envelope openings sealed? | N1104.8.2 |
| 9 _____ | Does slab insulation extend 24" downward vertically or horizontally? | N1104.7 |
| 10 _____ | Are vapor barriers installed? | N1104.9 |
| 11 _____ | Has insulation been spilt around pipes/wires/boxes? | N1104.2 |
| 12 _____ | Have insulation shields been installed around appliance vents? | N1104.2.4 |
| 13 _____ | Do exposed vapor barriers meet smoke and flame spread ratings? | R315.1 |
| 14 _____ | Have all holes in plates/firestops/tub traps been sealed? | R602.8 |
| 15 _____ | Have all plumbing vents been extended through the roof? | P3106.1 |
| 16 _____ | Are all previous corrections complete to allow sheetrock cover? | |

**This document may be revised at any time without notice