

# Exhibit O

**From:** Michael Schick <chief@wlfea.org>

**Sent:** Thursday, October 26, 2023 12:04 PM

**To:** Sharon Barker <sharon.barker@ci.florence.or.us>

**Subject:** RE: Referral Request for new Dollar General retail store Hwy 101, North of Burger King 18-12-23-22-06800

Sharon,

The Fire Department has no issues with emergency access or water supply for the planned development. We are highly encouraging the installation of an automatic sprinkler system but are not requiring it at this time. We are requiring a key box be placed on the exterior.