# CITY OF FLORENCE

## MANHOLE VACUUM TEST REPORT

EXHIBIT D

**PROJECT:** STONEFIELD **PROJECT #:** 21038,01

**CONTRACTOR:** RAY WELLS **TESTED BY:** ZEV/ BRANDON

**WITNESSED BY:** JWK **(INSPECTOR)**

| DATE | MH # or LOCATION | PAVED (P or U) | MH DEPTH | MH DIAM. | VACUUM DATA | | | PASS or FAIL | COMMENTS |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | TIME | START | END | | |
| 8-21-23 | EAST | P | 7.58' | 48" | 20 | 10 | 9.9 | P | |
| 8-21-23 | MIDDLE | P | 6.75' | 48" | 20 | 10 | 10 | P | |
| 8-21-23 | WEST | P | 8.6' | 48" | 25 | 10 | 9.9 | P | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |