

# EXHIBIT E

## PSS CITY OF FLORENCE WATER OR FIRE SYSTEM PRESSURE TEST FORM

DATE 5/3/23

SYSTEM TESTED STONEFIELD PRESSURE SS

AGREEMENT NUMBER \_\_\_\_\_

REQUESTING COMPANY RAY WELLS

REQUESTING INDIVIDUAL ZEV

ALL VALVES WITHIN SYSTEM CHECKED AND OPEN: Yes  NO

SYSTEM PRESSURE 50<sup>3</sup> Test Pressure 105

NUMBER OF GALLONS TO ACHIEVE TEST PRESSURE —

LENGTH OF TEST TIME 1 HR (ONE HOUR MINIMUM)

NUMBER OF GALLONS TO RE-ESTABLISH TEST PRESSURE —

INSPECTION BY JAKE KRIEGER

REMARKS LINE WAS LEFT OVERNIGHT WITH APPROX 100 PSI TO STABILIZE. INCREASED PRESSURE TO APPROX 105 PSI AND HELD WITH 0 LOSS. NO MAKEUP TEST REQUIRED

TESTED BY ZEV

PIPE SIZE	<u>4"</u>	LENGTH	<u>810</u>	ALLOW. LOSS	<u>—</u>
-----------	-----------	--------	------------	-------------	----------

PIPE SIZE	_____	LENGTH	_____	ALLOW. LOSS	_____
-----------	-------	--------	-------	-------------	-------

PIPE SIZE	_____	LENGTH	_____	ALLOW. LOSS	_____
-----------	-------	--------	-------	-------------	-------

PIPE SIZE	_____	LENGTH	_____	ALLOW. LOSS	_____
-----------	-------	--------	-------	-------------	-------

TOTAL ALLOWABLE GALLON LOSS N/A

PRESSURE TEST ACCEPTED\*  NOT APPROVED \_\_\_\_\_ BY JWK DATE 5/3/23

SYSTEM ACCEPTED\* \_\_\_\_\_ NOT APPROVED \_\_\_\_\_ BY \_\_\_\_\_ DATE \_\_\_\_\_

COMMENTS \_\_\_\_\_

Signature of Inspector: 