



**NOTES:**

- 1) RESIDENTIAL DRIVEWAYS AND SIDEWALK SECTIONS THROUGH DRIVEWAYS SHALL HAVE A MINIMUM NORMAL THICKNESS OF 6". CONCRETE STRENGTH SHALL BE 3300 PSI.
- 2) CONCRETE FOR COMMERCIAL USE AND ALLEY APPROACHES SHALL HAVE A MINIMUM NOMINAL THICKNESS OF 8". CONCRETE STRENGTH SHALL BE 3300 PSI.
- 3) CURB TRANSITIONS FOR COMMERCIAL USE AND ALLEY APPROACHES SHALL BE 5 FT.
- 4) CONSTRUCT CONTRACTION JOINT IN CENTER OF DRIVEWAY WHEN DRIVEWAY WIDTH EXCEEDS 15'.
- 5) NO LIP AT GUTTER IF USED AS SIDEWALK ACCESS RAMP.
- 6) SEE SIDEWALK DETAILS FOR RESTRICTIONS AND SPECIFICATIONS NOT SHOWN.
- 7) THE 50:1 CROSS-SLOPE OF SIDEWALK IS MEASURED FROM HORIZONTAL. THE 12:1 SLOPE OF SIDEWALK TRANSITION TO DRIVEWAY/ALLEY IS RELATIVE TO THE RUNNING SLOPE OF THE SIDEWALK. THE SLOPE OF THE APRON IS MEASURED RELATIVE TO HORIZONTAL.

**TYPICAL SECTION THROUGH RAMP**

**CITY OF FLORENCE  
STANDARD DRAWING**

**DRIVEWAY AND ALLEY  
APPROACHES FOR  
SETBACK OR  
BYPASS SIDEWALK**

DATE: MARCH 2007	DRAWING NO. F-208A
---------------------	-----------------------