



NOTES:

1. PIPE AND FITTINGS SHALL BE COMPATIBLE. ONLY MANUFACTURED FITTINGS SHALL BE USED. 3034 PIPE OR EQUAL SHALL BE USED.
2. MINIMUM DEPTH AT RIGHT OF WAY OR EASEMENT LINE SHALL BE 4 FEET.
3. MARKER POSTS AND BLOCKING SHALL BE TREATED WOOD. POST SHALL BE 2" X 4" FIR. POST TO EXTEND 4" MINIMUM ABOVE FINISH GRADE AND EXPOSED AREA SHALL BE PAINTED GREEN.
4. A CLEANOUT SHALL BE INSTALLED WHEN REQUIRED, W/ CAST IRON COVER. SEE FIGURE F-310 & FIGURE F-310A.
5. LAY BUILDING SEWER AT MAX. 45° FROM HORIZONTAL TO ACHIEVE REQUIRED DEPTH AT PROPERTY LINE WHEN MINIMUM SLOPE RESULTS IN EXCESSIVE DEPTH.

**CITY OF FLORENCE
STANDARD DRAWING**

**SEWER SERVICE
DETAIL**

REV: 12-01-11

DATE:

08-01-01

DRAWING NO.

F-308