



- NOTE:
1. ALL CLEANOUT MATERIAL TO BE SAME AS CARRIER PIPE
 2. USE CLEANOUT CAP OR SCREW CAP.
 3. MANHOLES REQUIRED ON DEAD END LINES.

NOTES:

1. PIPE FITTINGS SHALL BE COMPATIBLE. ONLY MFG. FITTINGS SHALL BE USED.
2. MINIMUM DEPTH AT RIGHT OF WAY OR EASEMENT LINE SHALL BE 4 FEET.
3. MARKER POSTS AND BLOCKING SHALL BE TREATED WOOD POST SHALL BE 2" X 4" FIR. POST TO EXTEND 4' MINIMUM ABOVE FINISH GRADE AND EXPOSED AREA SHALL BE PAINTED GREEN.
4. A CLEANOUT SHALL BE INSTALLED WHEN REQUIRED, W/CAST IRON COVER - SEE FIGURE F-310 & FIGURE F-310A.
5. LAY BUILDING SEWER AT MAX. 45° FROM HORIZONTAL TO ACHIEVE REQUIRED DEPTH AT PROPERTY LINE WHEN MINIMUM SLOPE RESULTS IN EXCESSIVE DEPTH.

**CITY OF FLORENCE
STANDARD DRAWING**

**SHALLOW TRENCH
SERVICE CONNECTION
BLOCKING AND
MARKERS W/CLEANOUT**

DATE:
10-2009

DRAWING NO.
F-309