



NOTE:

1. STANDARD PRECAST MANHOLE SECTION DIAMETER TO BE 48" (42" ONLY IF DIRECTED BY ENGINEER).
2. ALL PRECAST SECTIONS SHALL CONFORM TO REQUIREMENTS OF ASTM C 478.
3. ALL CONNECTING PIPE SHALL HAVE A FLEXIBLE JOINT WITHIN 18" OF MANHOLE WALL. IF THE PIPE IS PVC, IT SHALL BE EPOXY-SAND COATED WHERE IT IS GROUTED INTO THE MANHOLE.
4. CONSTRUCT OUTSIDE DROP PER THE DETAIL FOR 'OUTSIDE DROP CONNECTION FOR MANHOLES.'
5. ALL MANHOLES SHALL BE VACUUMED TESTED.

CITY OF FLORENCE STANDARD DRAWING	
POLLUTION CONTROL MANHOLE WITH OUTSIDE DROP	
REVISION: 3-9-10 ELIMINATE MH STEPS	
DATE: MARCH 2007	DRAWING NO. F-315c