



NOTE:

ONLY ONE INSIDE DROP CONNECTION ALLOWED PER MANHOLE.
 MINIMUM MANHOLE DIAMETER WITH DROP CONNECTION SHALL BE 48-INCHES.
 MAXIMUM DROP PIPE DIAMETER SHALL BE 8-INCHES.
 NOT TO BE USED FOR NEW CONSTRUCTION.

**CITY OF FLORENCE
 STANDARD DRAWING**

**DETAILS FOR INSIDE
 DROP CONNECTION
 FOR MANHOLES**

DATE:
 MARCH 2007

DRAWING NO.
 F-317