



Post Hydrants shall be non-freezing, self draining type with a 6" bury. These hydrants will be furnished with a 2" FIP inlet, a non-turning operating rod, and shall open to the left. All of the working parts shall be of bronze-to-bronze design, and be servicable from above grade with no digging. The outlet shall also be bronze and be 2-1/2" NST. Hydrants shall be lockable to prevent unauthorized use as manufactured by Kupferle Foundry Co., St. Louis, MO, or approved alternate.

CITY OF FLORENCE STANDARD DRAWING	
BLOW-OFF HYDRANT	
DATE: 9-23-11	DRAWING NO. F-402B